

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.45				Y
2	7.91				Y
3	7.87				Y
4	7.95				Y
5	7.98	61.59			Y
6	8.09				Y
7	8.20				Y
8	8.20				Y
9	8.17				Y
10	8.25				Y
11	8.22	47.80			Y
12	8.23				Y
13	8.00				Y
14	7.85				Y
15	7.87				Y
16	7.77				Y
17	7.87				Y
18	7.84	41.04			Y
19	7.85				Y
20	7.87				Y
21	7.86				Y
22	7.98				Y
23	7.99				Y
24	7.96				Y
25	7.85	61.59			Y
26	7.85				Y
27	7.93				Y
28	8.06				Y
29	8.05				Y
30	8.23				Y
31	8.04				Y

<<Have minimums been met for this day?	County: Tillamook Agency: REGION 1
	ENTRY POINT EP-A PWS ID 4100556 NETARTS WATER DISTRICT
Sample period: <u>MARCH 2024</u> Month/Year	

Number of excursions during this month: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:	
pH	7.4
Alk	40.0 (Alkalinity)

Print Name: David Hancock
 Signature: [Signature]
 Date & Phone#: 4/2/24 971-241-7203

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's