

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.05	61.99			Y
2	7.97				Y
3	7.94				Y
4	7.92				Y
5	8.00				Y
6	8.06				Y
7	8.08				Y
8	7.85	61.59			Y
9	7.96				Y
10	7.80				Y
11	7.86				Y
12	8.00				Y
13	7.83				Y
14	7.47				Y
15	7.87	61.59			Y
16	7.78				Y
17	7.88				Y
18	7.65				Y
19	7.98				Y
20	7.86				Y
21	7.66				Y
22	7.75	61.59			Y
23	7.87				Y
24	7.76				Y
25	7.81				Y
26	7.90				Y
27	7.80				Y
28	7.78				Y
29	8.10	47.88			Y
30	7.91				Y
31					

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT  
EP-A**

**PWS ID 4100556**

**NETARTS WATER DISTRICT**

Sample period: APRIL 2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.4  
Alk 40.0 (Alkalinity)

Print Name: DAVID Hancock  
Signature: *David Hancock*  
Date & Phone#: 5/2/24

503-842-9405  
971-241-7203

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0