

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.20				
2	8.54				
3	9.52				
4	9.81	75.24			
5	7.48				
6	7.52				
7	7.74				
8	7.74				
9	7.76				
10	7.60	75.24			
11	9.59				
12	10.31				
13	8.39				
14	8.46				
15	8.46				
16	8.27				
17	8.03	95.76			
18	8.05				
19	7.76				
20	7.76				
21	7.77				
22	7.88				
23	7.91				
24	8.24	57.72			
25	8.27				
26	8.13				
27	8.10				
28	8.25				
29	8.05				
30	7.81				
31					

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00556

System Name: NETARTS water District

Entry Point: EP-A EP FOR WTP

Sample Period: 11/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.40
Alk 40 (Alkalinity)
PO4 — (Orthophosphate)
Other ✓ ()

Print Name: DAVID Hancock

Signature: David Hancock

Date: 12/2/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0