

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	9.68				
2	8.01				
3	8.13				
4	8.20				
5	8.01	41.04			
6	7.96				
7	7.40				
8	8.17				
9	8.61				
10	8.53				
11	8.27				
12	8.63	41.04			
13	8.51				
14	8.42				
15	8.37				
16	8.10				
17	8.08				
18	8.06				
19	8.03	41.04			
20	8.08				
21	8.06				
22	8.10				
23	8.00				
24	7.96				
25	8.03				
26	8.32	41.04			
27	8.53				
28	8.51				
29	8.00				
30	7.96				
31	7.96				

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100556
NETARTS WATER DISTRICT**

Sample period: January 2026
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.4

Alk 40.0 (Alkalinity)

Print Name: David Hancock

Signature: [Signature]

Date & Phone#: 1/2/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0