

Day	pH	Alk	Phos	Other	Y/N
1	8.05				Y
2	8.03	41.04			Y
3	8.03				Y
4	8.06				Y
5	8.06				Y
6	8.06				Y
7	8.01				Y
8	7.89				Y
9	8.00	41.04			Y
10	7.88				Y
11	7.74				Y
12	8.01				Y
13	8.44				Y
14	8.46				Y
15	8.53				Y
16	8.83	68.4			Y
17	8.80				Y
18	8.66				Y
19	8.68				Y
20	8.63				Y
21	8.68				Y
22	8.70				Y
23	8.25	41.04			Y
24	8.01				Y
25	8.03				Y
26	8.05				Y
27	8.01				Y
28	8.01				Y
29	8.05				Y
30	8.05	47.88			Y
31	8.01				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00556

**System Name:** NETARTS WATER DISTRICT

**Entry Point:** WTP-A

**Sample Period:** 3/26 MARCH 2026  
Month/Year

**Number of excursions\* during this month:** \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.40	
Alk	40	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

**Print Name:** DAVID Hancock

**Signature:** *David Hancock*

**Date:** 4/1/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0