

# DHS

oregon department  
of human services

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.40				Y
2	7.46				Y
3	7.16				Y
4	7.18				Y
5	7.36				Y
6	7.29				Y
7	7.24				Y
8	7.23				Y
9	7.22				Y
10	7.15				Y
11	7.05				Y
12	7.13				Y
13	7.21				Y
14	7.20				Y
15	7.21				Y
16	7.20				Y
17	7.27				Y
18	7.03				Y
19	7.07				Y
20	7.08				Y
21	7.09				Y
22	7.06				Y
23	7.05				Y
24	7.06				Y
25	7.31				Y
26	7.46				Y
27	7.26				Y
28	7.21				Y
29	7.15				Y
30	7.23				Y
31	7.11				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?


		<b>ENTRY POINT</b>				
<b>PWS ID: 41</b>		0	0	5	5	7
<b>System Name:</b>		City of Newberg				
<b>Entry Point:</b>		Entry Point A				
<b>Sample Period:</b>		March-2021				
		Month / Year				

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For DHS use only*

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	7.00
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

**Print Name:** Daniel L Wilson  
**Signature:**   
**Date:** 4/1/2021

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350      Send to DHS within 10 days after end of sampling period      Phone: 971-673-0405