

# DHS

Oregon Department of Human Services

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.16				Y
2	7.11				Y
3	7.12				Y
4	7.10				Y
5	7.14				Y
6	7.14				Y
7	7.14				Y
8	7.04				Y
9	7.13				Y
10	7.20				Y
11	7.19				Y
12	7.19				Y
13	7.18				Y
14	7.01				Y
15	7.10				Y
16	7.16				Y
17	7.20				Y
18	7.24				Y
19	7.24				Y
20	7.16				Y
21	7.31				Y
22	7.13				Y
23	7.18				Y
24	7.12				Y
25	7.13				Y
26	7.11				Y
27	7.06				Y
28	7.01				Y
29	7.16				Y
30	7.14				Y
31					
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?	<b>ENTRY POINT</b>				
	<b>PWS ID: 41</b>	0	0	5	5
<b>System Name:</b>	City of Newberg				
<b>Entry Point:</b>	Entry Point A				
<b>Sample Period:</b>	April-2021				
	Month / Year				

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For DHS use only*

**Minimum Water Quality Parameters as set by State:**

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Daniel L Wilson  
**Signature:**   
**Date:** 5/3/2021

Send to DHS within 10 days after end of sampling period  
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: 971-673-0405