

DHS

oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.15				Y
2	7.17				Y
3	7.17				Y
4	7.18				Y
5	7.21				Y
6	7.21				Y
7	7.27				Y
8	7.37				Y
9	7.40				Y
10	7.43				Y
11	7.40				Y
12	7.24				Y
13	7.21				Y
14	7.10				Y
15	7.13				Y
16	7.11				Y
17	7.14				Y
18	7.16				Y
19	7.27				Y
20	7.16				Y
21	7.14				Y
22	7.09				Y
23	7.06				Y
24	7.05				Y
25	7.14				Y
26	7.04				Y
27	7.23				Y
28	7.29				Y
29	7.28				Y
30	7.26				Y
31	7.25				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

		ENTRY POINT				
PWS ID: 41		0	0	5	5	7
System Name:		City of Newberg				
Entry Point:		Entry Point A				
Sample Period:		May-2021				
		Month / Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.00
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name:	Pavil Snegirev
Signature:	
Date:	6/4/2021

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: 971-673-0405