

DHS

oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.22				Y
2	6.97				N
3	7.06				Y
4	7.11				Y
5	7.23				Y
6	7.36				Y
7	7.42				Y
8	7.23				Y
9	7.37				Y
10	7.28				Y
11	7.39				Y
12	7.27				Y
13	7.24				Y
14	7.30				Y
15	7.31				Y
16	7.33				Y
17	7.21				Y
18	7.12				Y
19	7.19				Y
20	7.17				Y
21	7.14				Y
22	7.14				Y
23	7.25				Y
24	7.26				Y
25	7.32				Y
26	7.16				Y
27	7.19				Y
28	7.14				Y
29	7.16				Y
30	7.21				Y
31					
(No = N = Excursion) Total N's					1

<< Have minimums been met for this day?	ENTRY POINT				
	PWS ID: 41	0	0	5	5
System Name:	City of Newberg				
Entry Point:	Entry Point A				
Sample Period:	June-2021				
	Month / Year				

Number of excursions* during this month: 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.00
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Daniel Wilson
Signature: 
Date: 7/1/2021