

DHS

oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.36				Y
2	7.41				Y
3	7.38				Y
4	7.29				Y
5	7.28				Y
6	7.22				Y
7	7.24				Y
8	7.14				Y
9	7.30				Y
10	7.30				Y
11	7.38				Y
12	7.49				Y
13	7.51				Y
14	7.52				Y
15	7.53				Y
16	7.51				Y
17	7.50				Y
18	7.47				Y
19	7.48				Y
20	7.50				Y
21	7.50				Y
22	7.34				Y
23	7.30				Y
24	7.31				Y
25	7.32				Y
26	7.31				Y
27	7.31				Y
28	7.31				Y
29	7.33				Y
30	7.39				Y
31					
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?	ENTRY POINT				
	PWS ID: 41	0	0	5	5
System Name:	City of Newberg				
Entry Point:	Entry Point A				
Sample Period:	November-2022				
	Month / Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Daniel L Wilson

Signature: 

Date: 12/1/2022

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Send to DHS within 10 days after end of sampling period Phone: 971-673-0405