

DHS

oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|--------------------------------|------|-----|------|------|-----|
| 1 | 7.26 | | | | Y |
| 2 | 7.32 | | | | Y |
| 3 | 7.30 | | | | Y |
| 4 | 7.33 | | | | Y |
| 5 | 7.39 | | | | Y |
| 6 | 7.48 | | | | Y |
| 7 | 7.40 | | | | Y |
| 8 | 7.41 | | | | Y |
| 9 | 7.36 | | | | Y |
| 10 | 7.48 | | | | Y |
| 11 | 7.53 | | | | Y |
| 12 | 7.51 | | | | Y |
| 13 | 7.46 | | | | Y |
| 14 | 7.43 | | | | Y |
| 15 | 7.41 | | | | Y |
| 16 | 7.38 | | | | Y |
| 17 | 7.40 | | | | Y |
| 18 | 7.45 | | | | Y |
| 19 | 7.41 | | | | Y |
| 20 | 7.39 | | | | Y |
| 21 | 7.40 | | | | Y |
| 22 | 7.41 | | | | Y |
| 23 | 7.41 | | | | Y |
| 24 | 7.51 | | | | Y |
| 25 | 7.53 | | | | Y |
| 26 | 7.54 | | | | Y |
| 27 | 7.53 | | | | Y |
| 28 | 7.49 | | | | Y |
| 29 | 7.39 | | | | Y |
| 30 | 7.52 | | | | Y |
| 31 | | | | | |
| (No = N = Excursion) Total N's | | | | | 0 |

<< Have minimums been met for this day?


| | | | | | | |
|-----------------------|--|--------------------|---|---|---|---|
| | | ENTRY POINT | | | | |
| PWS ID: 41 | | 0 | 0 | 5 | 5 | 7 |
| System Name: | | City of Newberg | | | | |
| Entry Point: | | Entry Point A | | | | |
| Sample Period: | | November-2023 | | | | |
| | | Month / Year | | | | |

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

| | |
|--|------------------|
| Minimum Water Quality Parameters as set by State: | |
| pH | 7.00 |
| Alk | (Alkalinity) |
| PO4 | (Orthophosphate) |
| Sili | (Silicate) |

Print Name: Daniel L Wilson
Signature: 
Date: 12/1/2023