



oregon department of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.34				Y
2	7.29				Y
3	7.31				Y
4	7.30				Y
5	7.33				Y
6	7.30				Y
7	7.19				Y
8	7.29				Y
9	7.42				Y
10	7.50				Y
11	7.40				Y
12	7.26				Y
13	7.22				Y
14	7.13				Y
15	7.09				Y
16	7.27				Y
17	7.30				Y
18	7.32				Y
19	7.32				Y
20	7.27				Y
21	7.27				Y
22	7.11				Y
23	7.10				Y
24	7.19				Y
25	7.12				Y
26	7.03				Y
27	7.09				Y
28	7.04				Y
29	7.10				Y
30					
31					
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

PWS ID: 41	ENTRY POINT				
	0	0	5	5	7

System Name:	City of Newberg
Entry Point:	Entry Point A
Sample Period:	February-2024
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Daniel L Wilson

Signature:

Date: 3/1/2024

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Send to DHS within 10 days after end of sampling period Phone: 971-673-0405