



oregon department of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.28				Y
2	7.21				Y
3	7.17				Y
4	7.16				Y
5	7.14				Y
6	7.41				Y
7	7.34				Y
8	7.19				Y
9	7.09				Y
10	7.14				Y
11	7.10				Y
12	7.16				Y
13	7.17				Y
14	7.08				Y
15	7.19				Y
16	7.19				Y
17	7.21				Y
18	7.20				Y
19	7.21				Y
20	7.18				Y
21	7.07				Y
22	7.02				Y
23	7.04				Y
24	7.06				Y
25	7.10				Y
26	7.11				Y
27	7.16				Y
28	7.40				Y
29	7.32				Y
30	7.27				Y
31					
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

		ENTRY POINT				
PWS ID: 41		0	0	5	5	7
System Name:		City of Newberg				
Entry Point:		Entry Point A				
Sample Period:		June-2024				
		Month / Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.00
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Daniel L Wilson

Signature: _____

Date: 7/1/2024

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Send to DHS within 10 days after end of sampling period Phone: 971-673-0405