

DHS

oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.36				Y
2	7.35				Y
3	7.24				Y
4	7.28				Y
5	7.39				Y
6	7.36				Y
7	7.31				Y
8	7.29				Y
9	7.29				Y
10	7.27				Y
11	7.36				Y
12	7.44				Y
13	7.35				Y
14	7.34				Y
15	7.33				Y
16	7.23				Y
17	7.26				Y
18	7.30				Y
19	7.39				Y
20	7.33				Y
21	7.41				Y
22	7.41				Y
23	7.45				Y
24	7.43				Y
25	7.44				Y
26	7.41				Y
27	7.25				Y
28	7.33				Y
29	7.19				Y
30	7.13				Y
31	7.11				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

		ENTRY POINT				
PWS ID: 41		0	0	5	5	7
System Name:		City of Newberg				
Entry Point:		Entry Point A				
Sample Period:		August-2024				
		Month / Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Daniel L Wilson

Signature: 

Date: 9/3/2024

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Send to DHS within 10 days after end of sampling period Phone: 971-673-0405