

DHS

Oregon Department of Human Services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.13				Y
2	7.18				Y
3	7.19				Y
4	7.20				Y
5	7.22				Y
6	7.24				Y
7	7.33				Y
8	7.32				Y
9	7.34				Y
10	7.33				Y
11	7.32				Y
12	7.24				Y
13	7.24				Y
14	7.16				Y
15	7.19				Y
16	7.23				Y
17	7.42				Y
18	7.45				Y
19	7.49				Y
20	7.51				Y
21	7.37				Y
22	7.33				Y
23	7.32				Y
24	7.24				Y
25	7.24				Y
26	7.35				Y
27	7.45				Y
28	7.46				Y
29	7.45				Y
30	7.47				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

PWS ID: 41

System Name: City of Newberg

Entry Point: Entry Point A

Sample Period: September-2024
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Pavil Snegirev

Signature: *Pavil Snegirev*

Date: 10/3/2024

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: 971-673-0405