

DHSoregon department
of human services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	ENTRY POINT									
1	7.44				Y	PWS ID: 41 <table border="1"><tr><td>0</td><td>0</td><td>5</td><td>5</td><td>7</td></tr></table>	0	0	5	5	7					
0	0	5	5	7												
2	7.43				Y											
3	7.47				Y											
4	7.29				Y											
5	7.34				Y											
6	7.37				Y											
7	7.40				Y											
8	7.40				Y											
9	7.42				Y											
10	7.41				Y											
11	7.42				Y											
12	7.39				Y											
13	7.42				Y											
14	7.36				Y											
15	7.31				Y											
16	7.35				Y											
17	7.29				Y											
18	7.29				Y											
19	7.22				Y											
20	7.27				Y											
21	7.33				Y											
22	7.32				Y											
23	7.30				Y											
24	7.30				Y											
25	7.33				Y											
26	7.36				Y											
27	7.20				Y											
28	7.45				Y											
29	7.53				Y											
30	7.54				Y											
31	7.48				Y											
(No = N = Excursion) Total N's						0										

System Name: City of Newberg

Entry Point: Entry Point A

Sample Period: December-2024
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only
Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Jon Hodgkins
Signature: Jon Hodgkins
Date: 12/2/2024

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: 971-673-0405