

DHSoregon department
of human services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.44				Y
2	7.42				Y
3	7.43				Y
4	7.31				Y
5	7.28				Y
6	7.24				Y
7	7.28				Y
8	7.36				Y
9	7.25				Y
10	7.21				Y
11	7.43				Y
12	7.45				Y
13	7.48				Y
14	7.51				Y
15	7.45				Y
16	7.33				Y
17	7.29				Y
18	7.30				Y
19	7.31				Y
20	7.32				Y
21	7.35				Y
22	7.25				Y
23	7.18				Y
24	7.34				Y
25	7.48				Y
26	7.46				Y
27	7.51				Y
28	7.46				Y
29	7.18				Y
30	7.33				Y
31	7.34				Y
(No = N = Excursion) Total N's					0

<< Have
minimums been
met for this day?

PWS ID: 41

00557

ENTRY POINT

System Name:

City of Newberg

Entry Point:

Entry Point A

Sample Period:

January-2025

Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by
State:

pH

7.00

Alk

(Alkalinity)

PO4

(Orthophosphate)


Sili

(Silicate)

Print Name:

Jon Hodgkins

Signature:



Date:

2/4/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: 971-673-0405

01-2025- PWS 41 00557 L&C CC