



oregon department
of human services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.42				Y
2	7.49				Y
3	7.45				Y
4	7.44				Y
5	7.26				Y
6	7.23				Y
7	7.22				Y
8	7.26				Y
9	7.28				Y
10	7.25				Y
11	7.31				Y
12	7.33				Y
13	7.23				Y
14	7.39				Y
15	7.39				Y
16	7.45				Y
17	7.42				Y
18	7.41				Y
19	7.28				Y
20	7.15				Y
21	7.30				Y
22	7.39				Y
23	7.38				Y
24	7.43				Y
25	7.45				Y
26	7.37				Y
27	7.23				Y
28	7.22				Y
29					Y
30					Y
31					Y
(No = N = Excursion) Total N's					0

<< Have
minimums been
met for this day?

PWS ID: 41

ENTRY POINT

0 0 5 5 7

System Name:

City of Newberg

Entry Point:

Entry Point A

Sample Period:

February-2025

Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by
State:

pH

7.00

Alk

(Alkalinity)

PO4

(Orthophosphate)

Sili

(Silicate)

Print Name:

Jon Hodgkins

Signature:

Jon Hodgkins

Date:

3/5/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: 971-673-0405