

DHSoregon department
of human services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.35				Y
2	7.37				Y
3	7.38				Y
4	7.40				Y
5	7.36				Y
6	7.36				Y
7	7.40				Y
8	7.49				Y
9	7.48				Y
10	7.47				Y
11	7.44				Y
12	7.44				Y
13	7.44				Y
14	7.44				Y
15	7.43				Y
16	7.42				Y
17	7.41				Y
18	7.34				Y
19	7.33				Y
20	7.42				Y
21	7.48				Y
22	7.46				Y
23	7.45				Y
24	7.48				Y
25	7.45				Y
26	7.34				Y
27	7.34				Y
28	7.34				Y
29	7.38				Y
30	7.39				Y
31	7.38				Y
(No = N = Excursion) Total N's					0

<< Have
minimums been
met for this day?

PWS ID: 41

00557

ENTRY POINT

System Name:

City of Newberg

Entry Point:

Entry Point A

Sample Period:

August-2025

Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by
State:

pH

7.00

Alk

(Alkalinity)

PO4

(Orthophosphate)


Sili

(Silicate)

Print Name:

Jon Hodgkins

Signature:



Date:

9/3/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: 971-673-0405

08-2025- PWS 41 00557 L&C CC