

DHS

Oregon Department of Human Services

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.30				Y
2	7.27				Y
3	7.20				Y
4	7.19				Y
5	7.12				Y
6	7.21				Y
7	7.27				Y
8	7.29				Y
9	7.35				Y
10	7.27				Y
11	7.21				Y
12	7.47				Y
13	7.44				Y
14	7.45				Y
15	7.31				Y
16	7.31				Y
17	7.18				Y
18	7.34				Y
19	7.29				Y
20	7.20				Y
21	7.21				Y
22	7.27				Y
23	7.27				Y
24	7.15				Y
25	7.32				Y
26	7.22				Y
27	7.30				Y
28	7.28				Y
29	7.31				Y
30	7.28				Y
31	7.42				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

		ENTRY POINT				
PWS ID: 41		0	0	5	5	7
System Name:		City of Newberg				
Entry Point:		Entry Point A				
Sample Period:		December-2025				
		Month / Year				

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.00	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Jon Hodgkins

Signature: *Jon Hodgkins*

Date: 1/5/2026

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Send to DHS within 10 days after end of sampling period Phone: 971-673-0405