

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | 7.5 | | | | y |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | 7.5 | | | | y |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | 7.6 | | | | y |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | 7.7 | | | | y |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00562

System Name: chehalem mt. sun ridge water co.

Entry Point: _____

Sample Period: July, 2021
Month/Year

Number of excursions* during this month: 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only _____

**Minimum Water Quality
Parameters as set by**

pH 
Alk (Alkalinity)
PO4 (Orthophosphate)
Other (_____)

Print Name: John Schaberg

Signature:  Type text here

Date: July 31, 2021

Send to DWP within 10 days after end of
sampling period