

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.9				Y
8					
9					
10					
11					
12					
13					
14	7.8				Y
15					
16					
17					
18					
19					
20	7.8				Y
21					
22					
23					
24					
25					
26					
27	8.1				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 00562

System Name: Chehalum Mt. Sun Ridge Water Co

Entry Point: 31555 NE Carter Ln, Sherwood, OR

Sample Period: December 2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2  
Alk \_\_\_\_\_ (Alkalinity)  
PO4 \_\_\_\_\_ (Orthophosphate)  
Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: Suzanne Boyd  
Signature: Suzanne M. Boyd  
Date: 12/27/2022

Send to DWP within 10 days after end of sampling period

\* = N = Excursion) Total N's 0