

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1						minimums ENTRY POINT
2						been met for this day? PWS ID: 41 0 0 5 6 2
3						System Name: Chehalem Mt. Sun Ridge Water
4						Entry Point: 31555 NE Canter Lane
5	7.8				У	
6						Sample Period: December 2023 Month/Year
7						
8						Number of excursions* during this month:
9						(Count the number of days when any WQP was less than the minimum required)
10						less than the minimum required)
11						Total avaragions during the granificant formula of
12	8.0				У	Total excursions during the previous 5 months: 0
13						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14						Tome and Distribution executions are carrialative)
15						For OHA use only
16						
17 18						Minimum Water Quality
19						Parameters as set by
20	7.0				у	pH 7.2
21	7.8				У	Alk (Alkalinity)
22						PO4 (Orthophosphate)
23						Other ()
24						
25						
26						
27						
28						Print Name: John Schaberg
29	7.8					Signature: john schaberg
30	7.0				У	Date: 12/29/23
31						Send to DWP within 10 days after end of
	l = Fx	L cursion) Tota	ı N'e		sampling period