

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.5				Y
7					
8					
9					
10					
11					
12					
13	7.4				y
14					
15					
16					
17					
18					
19					
20	7.6				y
21					
22					
23					
24					
25					
26					
27					
28	7.6				y
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
 minimums
 been met for
 this day?

ENTRY POINT
PWS ID: 41 00562
System Name: Chehalem Sun Ridge water
Entry Point: 31555 NE Canter Lane
Sample Period: Feb, 2024

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: john schaberg
Signature: john schaberg
Date: 2/28/24

Send to DWP within 10 days after end of sampling period