

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|----------------------------|-----|-----|------|-------|-----|
| 1 | 7.4 | | | | y |
| 2 | | | | | |
| 3 | | | | | |
| 4 | 7.5 | | | | y |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 7.2 | | | | y |
| 9 | 7.6 | | | | y |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | 7.5 | | | | y |
| 14 | | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | 7.2 | | | | y |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 7.6 | | | | y |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | 7.6 | | | | y |
| 28 | | | | | |
| 29 | | | | | |
| 30 | 7.5 | | | | y |
| 31 | | | | | |
| = N = Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00562

System Name: Chehalem Svn Ridge Water Co

Entry Point: 31555 NE Canter Lane, Sherwood, OR

Sample Period: MAY 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Suzanne Boyd

Signature: Suzanne M. Boyd

Date: May 30, 2024 (5/30/24)

Send to DWP within 10 days after end of sampling period