

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.4				Y
5					
6					
7					
8					
9	7.5				Y
10					
11					
12					
13					
14					
15					
16	7.5				Y
17					
18					
19					
20					
21					
22	7.6				Y
23					
24					
25					
26					
27					
28	7.5				Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Chehalem Sun Ridge Water

Entry Point: 31555 NE Canter lane

Sample Period: February 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Derek Easton

Signature:

Date: February 28, 2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's