

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.6				
8					
9					
10					
11					
12					
13					
14	7.5				
15					
16					
17					
18					
19					
20					
21	7.6				
22					
23					
24					
25					
26					
27					
28	7.7				
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00562

System Name: Chehalem Sun Ridge Water
 Entry Point: 31555 NE Canter Lane, Sherwood
 Sample Period: May, 2025
 Month/Year

Number of excursions* during this month: 2
 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Jennifer Easton

Signature: 

Date: 5/30/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's