

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.5				✓
4					
5					
6					
7					
8	6.6				N
9	6.6				N
10	7.4				✓
11	7.3				✓
12	7.7				✓
13					
14					
15	7.4				✓
16	7.6				✓
17					
18					
19					
20					
21					
22	7.7				✓
23					
24					
25					
26					
27					
28					
29	7.5				✓
30					
31					

(No = N = Excursion) Total N's

2

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00562

System Name: Chehalem Mt. Sunridge Water

Entry Point: 31555 NE. Canter Ln, Sherwood

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 2

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 3

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.2

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: Suzanne M. Boyd

Signature: Suzanne M. Boyd

Date: 6/29/25

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>