

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.9				Y
4					
5					
6					
7					
8					
9					
10	7.9				Y
11					
12					
13					
14					
15					
16					
17	7.9				Y
18					
19					
20					
21					
22					
23					
24	7.6				Y
25					
26					
27					
28					
29					
30					
31	7.7				Y

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00562

System Name: Chehalem Sun Ridge Mountain Water

Entry Point: 31555 NE Canter Lane



Sample Period: August 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Derek Easton

Signature: _____



Date: Aug 31, 2025

Send to DWP within 10 days after end of sampling period