

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.4				y
8					
9					
10					
11					
12					
13					
14	7.4				y
15					
16					
17					
18					
19					
20					
21	7.6				y
22					
23					
24					
25					
26					
27					
28	7.5				y
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Chehalem Sun Ridge Wtr.

Entry Point: 31555 NE Canter Ln.

Sample Period: October ,2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: john schaberg

Signature: john schaberg

Date: Oct, 2025

Send to DWP within 10 days after end of sampling period