

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6				Y
3					
4					
5					
6					
7					
8					
9	7.6				Y
10					
11					
12					
13					
14					
15					
16	7.4				Y
17					
18					
19					
20					
21					
22					
23	7.3				Y
24					
25					
26					
27					
28					
29					
30	7.6				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 5 6 2

System Name: Chehalem Sun Ridge Mountain Water

Entry Point: 31555 NE Canter Lane

Sample Period: November 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 3

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: Derek Easton

Signature: 

Date: Nov 30, 2025

Send to DWP within 10 days after end of sampling period