



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
6/5	7.3				Y
6/12	7.4				Y
6/19	7.0				Y
6/27	7.0				Y

<<Have minimums been met for this day?

County: Lincoln Agency: REGI

ENTRY POINT

EP-A

PWS ID 4100564

BAY HILLS WATER ASSOCIATION

Sample period: June 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: John MacKown

Signature: *John MacKown*

Date: 1 JUL 22

(No = N = Excursion) Total N's

Send to DWP within 10 days after end of sampling period