

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.4	30			Y
5					
6					
7					
8					
9					
10					
11					
12	7.3	30			Y
13					
14					
15					
16					
17					
18					
19					
20	7.1	30			Y
21					
22					
23					
24					
25					
26					
27					
28	7.0	30			Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 1/23                       
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only \_\_\_\_\_

**Minimum Water Quality Parameters as set by**

pH	7.0	
Alk	30	(Alkalinity)
PO4	n/a	(Orthophosphate)
Other	n/a	(_____)

Print Name: John MacKown

Signature: \_\_\_\_\_

Date: 4/3/23

Send to DWP within 10 days after end of sampling period