

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.2	35			Y
4					
5					
6					
7					
8					
9					
10	7.4	35			Y
11					
12					
13					
14					
15					
16	7.2	30			Y
17					
18					
19					
20					
21					
22					
23					
24	7.4	30			Y
25					
26					
27					
28					
29					
30	7.0	30			Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 1/23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only _____

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.0</td></tr></table>	7.0	
7.0			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td>n/a</td></tr></table>	n/a	(Orthophosphate)
n/a			
Other	<table border="1"><tr><td>n/a</td></tr></table>	n/a	(_____)
n/a			

Print Name: John MacKown

Signature: _____

Date: 6/4/23

Send to DWP within 10 days after end of sampling period