

Day	pH	Alk	Phos	Other	Y/N
1	7.5	35			Y
2	PD				
3	PD				
4	PD				
5	PD				
6	PD				
7	7.3	40			Y
8	PD				
9	PD				
10	PD				
11	PD				
12	PD				
13	PD				
14	PD				
15	PD				
16	PD				
17	PD				
18	PD				
19	PD				
20	PD				
21	PD				
22	PD				
23	PD				
24	7.8	40			Y
25	7.4	35			Y
26	7.0	35			Y
27	PD				
28	7.3	35			Y
29	PD				
30	PD				
31	PD				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00564

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 1/23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
 Alk 30 *(Alkalinity)*
 PO4 n/a *(Orthophosphate)*
 Other n/a *(_____)*

Print Name: John MacKown

Signature: _____

Date: 8/2/2023

Send to DWP within 10 days after end of sampling period

PD=PLANTDOWN