

Day	pH	Alk	Phos	Other	Y/N
1	7.1	35			Y
2					
3					
4					
5					
6					
7					
8					
9	7.0	30			Y
10					
11					
12					
13	7.4	30			Y
14					
15					
16					
17					
18					
19	7.2	30			Y
20					
21					
22					
23					
24					
25					
26					
27	7.2	30			Y
28					
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 12/23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.0

Alk

30

(Alkalinity)

PO4

n/a

(Orthophosphate)

Other

n/a

(_____)

Print Name: John MacKown

Signature: _____

Date: 1-1-24

Send to DWP within 10 days after end of sampling period