

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.2	35			Y
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.5	35			Y
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.1	30			Y
26					
27					
28					
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: March 2024

*Month/Year*

Number of excursions\* during this month: 0

*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.0</td></tr></table>	7.0	
7.0			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	<i>(Alkalinity)</i>
30			
PO4	<table border="1"><tr><td>n/a</td></tr></table>	n/a	<i>(Orthophosphate)</i>
n/a			
Other	<table border="1"><tr><td>n/a</td></tr></table>	n/a	<i>(_____)</i>
n/a			

Print Name: John MacKown

Signature: \_\_\_\_\_

Date: 4-2-2024

Send to DWP within 10 days after end of sampling period