

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	PD				
2	PD				
3	PD				
4	PD				
5	PD				
6	7.0	40			Y
7	PD				
8	PD				
9	PD				
10	PD				
11	PD				
12	PD				
13	PD				
14	PD				
15	PD				
16	PD				
17	PD				
18	PD				
19	PD				
20	PD				
21	PD				
22	PD				
23	PD				
24	PD				
25	7.8	34			Y
26	7.5	40			Y
27	7.6	36			Y
28	PD				
29	PD				
30	PD				
31	PD				
PD = Plant Down					0

(No = N = Excursion)

**Total N's**

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 7/24  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.0</td></tr></table>	7.0	
7.0			
Alk	<table border="1"><tr><td>30</td></tr></table>	30	(Alkalinity)
30			
PO4	<table border="1"><tr><td>n/a</td></tr></table>	n/a	(Orthophosphate)
n/a			
Other	<table border="1"><tr><td>n/a</td></tr></table>	n/a	(_____)
n/a			

Print Name: John MacKown

Signature: \_\_\_\_\_

Date: 8/1/24

Send to DWP within 10 days after end of sampling period