

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/ N
1	7.0	35			Y
2	PD				
3	PD				
4	PD				
5	PD				
6	PD				
7	7.0	40			Y
8	PD				
9	PD				
10	PD				
11	PD				
12	PD				
13	PD				
14	PD				
15	PD				
16	PD				
17	PD				
18	PD				
19	PD				
20	PD				
21	PD				
22	PD				
23	PD				
24	PD				
25	7.0	40			Y
26	7.6	40			Y
27	7.9	40			Y
28	PD				
29	7.2	40			Y
30	PD				
31	PD				
Total N's					0

(No = N = Excursion)

<<Have

minimums

been met for

this day?

ENTRY POINT

PWS ID: 41

0	0	5	6	4
---	---	---	---	---

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 7/25

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk 30 (Alkalinity)

PO4 n/a (Orthophosphate)

Other n/a (_____)

Print Name: John MacKown

Signature: _____

Date 8/1/25

Send to DWP within 10 days after end of sampling period

PD=Plant Down