

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/ N |
|------------------|-----|-----|------|-------|----------|
| 1 | PD | | | | |
| 2 | PD | | | | |
| 3 | PD | | | | |
| 4 | 7.4 | 32 | | | Y |
| 5 | PD | | | | |
| 6 | PD | | | | |
| 7 | 7.4 | 32 | | | Y |
| 8 | PD | | | | |
| 9 | PD | | | | |
| 10 | PD | | | | |
| 11 | PD | | | | |
| 12 | 7.3 | 32 | | | Y |
| 13 | PD | | | | |
| 14 | PD | | | | |
| 15 | PD | | | | |
| 16 | PD | | | | |
| 17 | PD | | | | |
| 18 | 7.0 | 35 | | | Y |
| 19 | PD | | | | |
| 20 | PD | | | | |
| 21 | PD | | | | |
| 22 | PD | | | | |
| 23 | PD | | | | |
| 24 | PD | | | | |
| 25 | 7.0 | 40 | | | Y |
| 26 | PD | | | | |
| 27 | PD | | | | |
| 28 | PD | | | | |
| 29 | PD | | | | |
| 30 | PD | | | | |
| 31 | PD | | | | |
| Total N's | | | | | 0 |

(No = N = Excursion)

<<Have

minimums

been met for

this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 5 | 6 | 4 |
|---|---|---|---|---|

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period 8/25

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.0

Alk

30

(Alkalinity)

PO4

n/a

(Orthophosphate)

Other

n/a

(_____)

Print Name: John MacKown

Signature: _____

Date 9/2/25

Send to DWP within 10 days after end of sampling period

PD=Plant Down