

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	PD				
2	7.2	40			Y
3	PD				
4	PD				
5	PD				
6	PD				
7	PD				
8	PD				
9	PD				
10	PD				
11	7.1	40			Y
12	PD				
13	PD				
14	PD				
15	PD				
16	PD				
17	PD				
18	7.5	40			Y
19	PD				
20	PD				
21	PD				
22	PD				
23	PD				
24	PD				
25	PD				
26	PD				
27	PD				
28	7.5	38			Y
29	PD				
30	PD				
31	PD				
<b>Total N's</b>					0

(No = N = Excursion)

<<Have  
minimums  
been met for  
this day?

## ENTRY POINT

PWS ID: 41 0 0 5 6 4

System Name: Bay Hills Water Association

Entry Point: Treatment Plant

Sample Period: 10/25

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality  
Parameters as set by

pH	7.0
Alk	30
PO4	n/a
Other	n/a

(Alkalinity)  
(Orthophosphate)  
(\_\_\_\_\_)

Print Name: John MacKown

Signature: \_\_\_\_\_

Date 11/1/25 \_\_\_\_\_

Send to DWP within 10 days after end of  
sampling period

PD=Plant Down