

Water Quality Parameter Monitoring Form  
Oregon Department of Human Services  
**Lead & Copper Rule Corrosion Control**

Day	PH	Y/N
1	8.0	Y
2	7.9	Y
3	7.9	Y
4	7.9	Y
5	7.9	Y
6	7.9	Y
7	7.9	Y
8	7.9	Y
9	7.9	Y
10	8.0	Y
11	8.0	Y
12	8.0	Y
13	8.0	Y
14	8.0	Y
15	7.9	Y
16	7.9	Y
17	7.9	Y
18	7.9	Y
19	7.9	Y
20	7.8	Y
21	7.9	Y
22	7.9	Y
23	7.9	Y
24	7.8	Y
25	7.8	Y
26	7.8	Y
27	7.9	Y
28	7.9	Y
<b>Total N's</b>		<b>0</b>

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2  
**ENTRY POINT**  
EP- A (WTP)  
**PWS ID 4100566**  
City of Newport  
Sample period: Feb-21

**Number of excursions during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.0

Print Name: Steve Stewart

Signature: 

Date: 3/2/2021

Sent to DWP within 10 days after end of sampling period.