

Water Quality Parameter Monitoring Form  
Oregon Department of Human Services  
**Lead & Copper Rule Corrosion Control**

Day	PH	Y/N
1	8.0	Y
2	7.9	Y
3	7.9	Y
4	7.9	Y
5	8.0	Y
6	8.0	Y
7	8.0	Y
8	8.0	Y
9	8.0	Y
10	8.0	Y
11	7.9	Y
12	8.0	Y
13	8.0	Y
14	8.0	Y
15	8.0	Y
16	8.0	Y
17	8.0	Y
18	8.0	Y
19	8.0	Y
20	8.0	Y
21	8.0	Y
22	8.0	Y
23	8.0	Y
24	8.0	Y
25	8.1	Y
26	8.1	Y
27	8.1	Y
28	8.1	Y
<b>Total N's</b>		<b>0</b>

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2  
**ENTRY POINT**  
EP- A (WTP)  
**PWS ID 4100566**  
City of Newport  
  
Sample period: Feb-22

**Number of excursions during this month:** 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0

Print Name: Steve Stewart

Signature: 

Date: 3/1/2022

Sent to DWP within 10 days after end of sampling period.