

Water Quality Parameter Monitoring Form
Oregon Department of Human Services
Lead & Copper Rule Corrosion Control

Day	PH	Y/N
1	8.0	Y
2	8.0	Y
3	8.1	Y
4	8.0	Y
5	8.0	Y
6	7.9	Y
7	7.9	Y
8	7.8	Y
9	7.9	Y
10	7.9	Y
11	7.9	Y
12	7.9	Y
13	7.8	Y
14	7.8	Y
15	7.7	Y
16	7.7	Y
17	7.7	Y
18	7.8	Y
19	7.8	Y
20	7.8	Y
21	7.8	Y
22	7.8	Y
23	7.9	Y
24	7.9	Y
25	7.9	Y
26	8.0	Y
27	7.9	Y
28	7.9	Y
29	7.9	Y
30	7.9	Y
Total N's	0	

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2
ENTRY POINT
EP- A (WTP)
PWS ID 4100566
City of Newport
Sample period: Sep-22

Number of excursions during this month: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Print Name: Steve Stewart

Signature: 

Date: 10/4/2022

Sent to DWP within 10 days after end of sampling period.