

Water Quality Parameter Monitoring Form  
Oregon Department of Human Services  
**Lead & Copper Rule Corrosion Control**

Day	PH	Y/N
1	7.9	Y
2	7.9	Y
3	7.9	Y
4	7.9	Y
5	7.9	Y
6	8.0	Y
7	8.0	Y
8	8.1	Y
9	8.0	Y
10	8.0	Y
11	8.0	Y
12	8.0	Y
13	8.0	Y
14	8.1	Y
15	8.1	Y
16	7.9	Y
17	7.9	Y
18	7.8	Y
19	7.9	Y
20	7.9	Y
21	7.9	Y
22	7.8	Y
23	7.8	Y
24	7.8	Y
25	7.8	Y
26	7.8	Y
27	7.7	Y
28	7.7	Y
29	7.7	Y
30	7.7	Y
31		
<b>Total N's</b>		<b>0</b>

<<Have minimums been met for this day?

County: Lincoln

Agency: REGION 2

**ENTRY POINT**

EP- A (WTP)

**PWS ID 4100566**

City of Newport

Sample period: Nov-22


**Number of excursions during this month:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

<b>Minimum Water Quality Parameter(s) as set by State:</b>	
pH	<b>7.0</b>

Print Name: Steve Stewart

Signature 

Date: 12/1/2022

Sent to DWP within 10 days after end of sampling period.