

Water Quality Parameter Monitoring Form
Oregon Department of Human Services
Lead & Copper Rule Corrosion Control

Day	PH	Y/N
1	7.9	Y
2	7.9	Y
3	7.9	Y
4	8.0	Y
5	8.0	Y
6	7.9	Y
7	7.9	Y
8	7.9	Y
9	8.1	Y
10	8.3	Y
11	8.2	Y
12	8.1	Y
13	8.0	Y
14	8.0	Y
15	8.0	Y
16	8.0	Y
17	8.0	Y
18	8.0	Y
19	8.0	Y
20	8.0	Y
21	7.9	Y
22	8.0	Y
23	8.0	Y
24	8.0	Y
25	8.0	Y
26	8.0	Y
27	7.9	Y
28	7.9	Y
Total N's		0

<<Have minimums been met for this day?

County: Lincoln

Agency: REGION 2

ENTRY POINT

EP- A (WTP)

PWS ID 4100566

City of Newport

Sample period: Feb-23

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:	
pH	7.0

Print Name: Steve Stewart

Signature: 

Date: 3/1/2023

Sent to DWP within 10 days after end of sampling period.