

Water Quality Parameter Monitoring Form
Oregon Department of Human Services
Lead & Copper Rule Corrosion Control

Day	PH	Y/N
1	7.9	Y
2	7.9	Y
3	7.9	Y
4	7.9	Y
5	7.9	Y
6	7.9	Y
7	7.9	Y
8	7.9	Y
9	7.9	Y
10	7.9	Y
11	7.8	Y
12	7.8	Y
13	7.8	Y
14	7.8	Y
15	7.8	Y
16	7.7	Y
17	7.7	Y
18	7.7	Y
19	7.7	Y
20	7.7	Y
21	7.7	Y
22	7.6	Y
23	7.6	Y
24	7.6	Y
25	7.7	Y
26	7.7	Y
27	7.7	Y
28	7.7	Y
29	7.7	Y
30	7.7	Y
31	7.7	Y
Total N's		0

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2
ENTRY POINT
EP- A (WTP)
PWS ID 4100566
City of Newport
Sample period: Mar-23

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Print Name: Steve Stewart

Signature: 

Date: 4/1/2023

Sent to DWP within 10 days after end of sampling period.

(No = N = Excursion)