

Water Quality Parameter Monitoring Form  
Oregon Department of Human Services  
**Lead & Copper Rule Corrosion Control**

Day	PH	Y/N
1	7.9	Y
2	7.9	Y
3	7.9	Y
4	7.9	Y
5	7.9	Y
6	7.9	Y
7	8.0	Y
8	8.0	Y
9	7.9	Y
10	7.9	Y
11	8.0	Y
12	8.0	Y
13	8.1	Y
14	8.1	Y
15	8.0	Y
16	7.9	Y
17	7.9	Y
18	7.9	Y
19	7.8	Y
20	7.8	Y
21	7.8	Y
22	7.7	Y
23	7.7	Y
24	7.7	Y
25	7.7	Y
26	7.7	Y
27	7.7	Y
28	7.6	Y
<b>Total N's</b>		<b>0</b>

(No = N = Excursion)

<<Have minimums been  
met for this day?

County: Lincoln

Agency: REGION 2

**ENTRY POINT**

EP- A (WTP)

**PWS ID 4100566**

City of Newport

Sample period: Feb-25

**Number of excursions during this month:**

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH

**7.0**

Print Name: Steve Stewart

Signature: 

Date: 3/3/2025

Sent to DWP within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone: (971)-673-0471 Website: [www.dhs.state.or.us/publichealth/dwp/index.cfm](http://www.dhs.state.or.us/publichealth/dwp/index.cfm)