

Water Quality Parameter Monitoring Form  
Oregon Department of Human Services  
**Lead & Copper Rule Corrosion Control**

| Day              | PH  | Y/N      |
|------------------|-----|----------|
| 1                | 7.6 | Y        |
| 2                | 7.6 | Y        |
| 3                | 7.7 | Y        |
| 4                | 7.7 | Y        |
| 5                | 7.6 | Y        |
| 6                | 7.6 | Y        |
| 7                | 7.7 | Y        |
| 8                | 7.7 | Y        |
| 9                | 7.6 | Y        |
| 10               | 7.6 | Y        |
| 11               | 7.7 | Y        |
| 12               | 7.7 | Y        |
| 13               | 7.8 | Y        |
| 14               | 7.9 | Y        |
| 15               | 7.8 | Y        |
| 16               | 7.9 | Y        |
| 17               | 7.9 | Y        |
| 18               | 7.9 | Y        |
| 19               | 7.8 | Y        |
| 20               | 7.7 | Y        |
| 21               | 7.7 | Y        |
| 22               | 7.8 | Y        |
| 23               | 7.6 | Y        |
| 24               | 7.5 | Y        |
| 25               | 7.6 | Y        |
| 26               | 7.6 | Y        |
| 27               | 7.7 | Y        |
| 28               | 7.8 | Y        |
| 29               | 7.8 | Y        |
| 30               | 7.9 | Y        |
| <b>Total N's</b> |     | <b>0</b> |

(No = N = Excursion)

<<Have minimums been met for this day?

County: Lincoln

Agency: REGION 2

**ENTRY POINT**  
EP- A (WTP)  
**PWS ID 4100566**  
City of Newport

Sample period: Jun-25

**Number of excursions during this month:** 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.0

Print Name: Steve Stewart

Signature: 

Date: 7/2/2025

Sent to DWP within 10 days after end of sampling period.