

Water Quality Parameter Monitoring Form
Oregon Department of Human Services
Lead & Copper Rule Corrosion Control

Day	PH	Y/N
1	7.7	Y
2	7.6	Y
3	7.7	Y
4	7.8	Y
5	7.8	Y
6	7.7	Y
7	7.7	Y
8	7.8	Y
9	7.8	Y
10	7.7	Y
11	7.6	Y
12	7.6	Y
13	7.7	Y
14	8.0	Y
15	8.0	Y
16	8.0	Y
17	7.9	Y
18	7.8	Y
19	8.0	Y
20	7.9	Y
21	8.0	Y
22	7.9	Y
23	8.0	Y
24	7.9	Y
25	8.0	Y
26	8.1	Y
27	8.2	Y
28	8.0	Y
29	8.0	Y
30	8.0	Y
31	7.9	Y
Total N's		0

<<Have minimums been
met for this day?

County: Lincoln

Agency: REGION 2

ENTRY POINT
EP- A (WTP)
PWS ID 4100566
City of Newport

Sample period: Aug-25

Number of excursions during this month:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.


Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.0

Print Name: Steve Stewart

Signature: 

Date: 9/2/2025

Sent to DWP within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (971)-673-0471 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm